



August 7, 2019

# TOWN OF GREENWICH

Purchasing Department (203) 622-7881 Fax: (203) 622-7776  
Town Hall • 101 Field Point Road • Greenwich, CT 06830

## **\*\*ADDENDUM #3\*\***

### **TOWN OF GREENWICH**

#### **REQUEST FOR PROPOSAL #7508 DEADLINE: 8/21/19 AT 3:00 P.M.**

#### **GREENWICH POLICE DEPARTMENT FIREARMS RANGE INTERIOR IMPROVEMENTS & UPGRADE**

Additions to RFP #7508:

- Statement 1:** Construction of the range upgrade may take place over the winter months. The range heating units are part of the range exhaust system and will be removed prior to construction. Therefore, the awarded company for this project will be responsible for providing a temporary electric heating source with a thermostat properly wired into the existing building distribution panel.
- Statement 2:** Respondents are reminded that the Police Range is located on the Second Floor of the building. There is no direct access into the range other than by stairs and through a 3'-0" opening.
- Statement 3:** Respondents are to present the method to be employed to monitor the new range ventilation, including air flow measuring into and out of the range, filter status, range temperature, etc.
- Statement 4:** Respondents are reminded to include a full maintenance procedure and a projected yearly cost to maintain their suggested bullet trap.

On-site presentations will tentatively be scheduled during the week of August 26<sup>th</sup>.

**ALL OTHER SPECIFICATIONS, TERMS, AND CONDITIONS OF THIS RFP REMAIN UNCHANGED.**

Renata Michalski  
Senior Buyer